



TEST REPORT

Report No. MAN:HL:1548006901

ISSUE DATE: 13-Sep-2024



GREENLAM INDUSTRIES LIMITED
VILLAGE-PATERH BHONKU, P.O PANJEHRA,
TEHSIL NALAGARH, DISTT. SOLAN, HIMACHAL PRADESH- 174101
INDIA
CONTACT PERSON: MR. GSRA SHARMA

THE FOLLOWING SAMPLE(S) WAS/WERE SUBMITTED AND IDENTIFIED BY/ON BEHALF OF THE CUSTOMER AS :
SAMPLE DESCRIPTION GREENLAM HIGH PRESSURE DECORATIVE LAMINATE BLACK KRAFT SUEDE 13 MM

LAB PROVIDED DETAILS:
CONDITION OF SAMPLE COMPLETE AND OK
THE LOCATION OF PERFORMANCE OF THE LABORATORY ACTIVITIES: SGS PUNE LABORATORY
SAMPLE RECD ON 02-Sep-2024 **TESTING PERIOD :** 02-Sep-2024 - 13-Sep-2024

SUMMARY OF TEST RESULTS:

TESTS	PASS	FAIL	REMARKS
ASBESTOS TEST			SEE RESULT

Remarks: P=Pass

F=Fail

TEST(S) RESULT & METHOD: PLEASE REFER TO NEXT PAGE(S). RESULTS APPLY TO THE SAMPLE AS RECEIVED

Per Pro SGS India Pvt. Ltd.

SANDIP BHUSHAN
TECHNICAL MANAGER
Authorized Signatory-Mechanical
Email your Test Report Related Enquiries at Feedback.HLT@sgs.com

TEST REPORT

Report No. MAN:HL:1548006901

ISSUE DATE: 13-Sep-2024



NON ACCREDITED TEST(S)

TEST RESULT:

ASBESTOS TEST:

Method: With reference to JIS A 1481-1 (2016) ISO 22262-1 (2012); Analysis was performed by Stereo Microscope (SM), and Dispersion Staining Polarized Light Microscope (DS-PLM). And screening qualitative Analysis by XRD.

Reference: JIS A 1481-1 (2016) ISO 22262-1 (2012) Shimadzu Application Note-Surface Analysis Business Unit.

TEST NAME	TEST RESULT	REQUIREMENT
Chrysotile (CAS No.: 12001-29-5)	Negative	/
Amosite (CAS No.: 12172-73-5)	Negative	/
Crocidolite (CAS No.: 12001-28-4)	Negative	/
Anthophyllite (CAS No.: 77536-67-5)	Negative	/
Tremolite (CAS No.: 77536-68-6)	Negative	/
Actinolite (CAS No.: 77536-66-4)	Negative	/

Tested Item: GREENLAM HIGH PRESSURE DECORATIVE LAMINATE BLACK KRAFT SUEDE 13 MM

Note:

- Test has been sub-contracted to ISO/IEC 17025 accredited laboratory.
- Testing has been performed as per customer request.

TEST REPORT

Report No. **MAN:HL:1548006901**

ISSUE DATE: **13-Sep-2024**



Sample as Received



*****END OF REPORT*****